

PSC NO: 15 ELECTRICITY

LEAF: 268

COMPANY: CENTRAL HUDSON GAS &amp; ELECTRIC CORPORATION

REVISION: 3

INITIAL EFFECTIVE DATE: 04/01/12

SUPERSEDING REVISION: 2

Issued in Compliance with Order Establishing Filing Requirements dated November 21, 2011

**SERVICE CLASSIFICATION NO. 13** (Cont'd)**LARGE POWER SUBSTATION AND TRANSMISSION SERVICE** (Cont'd)**SPECIAL PROVISIONS** (Cont'd)

- 13.12 Non-Residential Fuel Cell Generation - Customers that own, lease or operate fuel cell generating equipment, as defined by Public Service Law Section 66-j, may supply their electric load and sell electric energy to the Company as set forth in General Information Section 3.C.

The rated capacity of a customer's generating equipment will be limited to 1,500 kW.

The total photovoltaic and farm waste generator load, micro-combined heat and power generator load, fuel cell generator load and micro-hydroelectric generator load on Central Hudson's system may not exceed 12 MW.

Interconnection costs will be charged by Central Hudson for a dedicated transformer(s) or other equipment, should it be determined to be necessary for safety and adequacy of service, pursuant to Addendum New York State Interconnection Requirements. In no event will such costs for micro-hydroelectric be less than the Company's costs.

In the event that the total rated generating capacity of electric generating equipment that provides electricity to the Company through the same local feeder line exceeds twenty percent of the rated capacity of the local feeder line, the customer owning or operating such equipment may be required to comply with additional measures to ensure the safety of the local feeder line. Wiring and switches of these facilities may be arranged in parallel so as to permit the flow of current from the Customer to the Company and vice versa.

Metering configuration will be determined by the Company. In the event that:

- (i) the Company determines that a second meter is a necessary part of an interconnection, the costs of such meter installation will be considered to be interconnection costs pursuant to Addendum New York State Standardized Interconnection Requirements, but shall not be deemed necessary for safety and adequacy of service;
- (ii) the Company requires a second meter installation that is not a necessity for interconnection, the costs of such meter installation shall be borne by the Company; or,
- (iii) the customer elects a second meter installation, the meter shall be treated as a component of the customer's generation system and the customer shall bear the cost of such meter installation.

Issued by: Michael L. Mosher, Vice President, Poughkeepsie, New York