

PSC NO: 11 – Electricity
Consolidated Edison Company of New York, Inc.
Initial Effective Date: 02/20/2012

Leaf: 4
Revision: 0
Superseding Revision:

ECONOMIC DEVELOPMENT DELIVERY SERVICE

Applicable to Use of Service for

The delivery of power and associated energy to Customers pursuant to the agreements referenced on Leaf No. 2 of this Rate Schedule and subject to the provisions of this Rate Schedule.

Character of Service

The following characteristics of service are available under this Rate Schedule, subject to the provisions of General Rule 4 of the Schedule for Electricity. The frequencies and voltages shown below are approximate. All are continuous.

Standard Service

Any derivative of the standard alternating current, 3 phase, 4 wire system at 60 cycles and 120/208 volts.

Non-Standard Service

Low Tension Alternating Current - 60 cycles:

Single phase at 120/240 volts
Three phase at 265/460 volts
Three phase at 240 volts
Two phase at 120/240 or 230 or 240 volts

High Tension Alternating Current - 60 cycles:

Three phase at 2,400/4,150 volts
Three phase at 3,000 or 7,800 volts
Three phase at 6,900 volts
Three phase at 13,200 volts
Three phase at 26,400 volts
Three phase at 33,000 volts
Single phase and three phase at 2,400 volts
Three phase at 69,000 volts
Three phase at 138,000 volts

Issued by: Robert Hoglund, Senior Vice President & Chief Financial Officer, New York, NY