

PSC NO: 12 GAS
COMPANY: THE BROOKLYN UNION GAS COMPANY
INITIAL EFFECTIVE DATE: 12/01/11
STAMPS: Issued in compliance with order in Case 11-G-0411 dated November 18, 2011

LEAF: 379.2
REVISION: 0
SUPERSEDING REVISION:

SERVICE CLASSIFICATION No. 18 – Continued

F. 4. Remote Switchover of Dual Fuel Equipment: (continued)

Customers with Semi-Automatic Equipment

When the Company receives a report that the Central Park Temperature has reached the Designated Interruption Temperature for Customers with automatic equipment, the Company will remotely activate an alarm at the semi-automatic Customer sites notifying such Customers to manually switchover to an alternate fuel (“Company initiated interruption”). If the alarm was activated remotely, the Customer may manually switch back to natural gas once the Central Park Temperature reaches the Designated Resumption Temperature for Customers with semi-automatic equipment. If the Local Outside Temperature reached the Designated Interruption Temperature and the Designated Interruption Temperature had not been reached at Central Park, the Customer may manually switch back to natural gas once the Local Outside Temperature reaches the Designated Resumption Temperature.

Issued by: Kenneth D. Daly, President, Brooklyn, New York