

PSC NO: 8 GAS
NATIONAL FUEL GAS DISTRIBUTION CORPORATION
INITIAL EFFECTIVE DATE: 02/01/12

LEAF: 37.2
REVISION: 0
SUPERSEDING REVISION:

GENERAL INFORMATION

II. 7. METERS AND REGULATORS - Continued

g. Gas Quality Requirements for Production Facilities

Gas which is received by the Company shall not contain more than:

- (a) seven (7) pounds of water (H₂O) in a vapor state per million cubic feet of gas;
- (b) three tenths (0.3) of a grain of hydrogen sulfide (H₂S) per one hundred (100) feet of gas;
- (c) twenty (20) grains of total sulphur (S) per one hundred (100) cubic feet of gas;
- (d) four percent (4%) by volume of a combined total of carbon dioxide (CO₂) and nitrogen (N₂) components provided, however, that the total carbon dioxide (CO₂) content shall not exceed two percent (2%) volume;
- (e) two tenths of one percent (0.2%) by volume of oxygen (O₂). Customer further agrees to make every effort to keep the gas completely free of oxygen (O₂).

Minimum heat content of gas received by the Company shall be one thousand British Thermal Units (1,000 BTU) per cubic foot (dry).

8. METER READING, BILLING AND COLLECTION

a. Meters and Billing Period

At the option of the Company, meters shall be read either monthly or bi-monthly. If the meter reading of a Customer is for a consumption period greater or less than a billing month, the stated rates shall apply pro-rata to the nearest full day of usage.

Issued by A. M. Cellino, President, 6363 Main Street, Williamsville, NY 14221
(Name of Officer, Title, Address)