

**P.S.C. NO. 3 ELECTRICITY**  
**ORANGE AND ROCKLAND UTILITIES, INC.**  
INITIAL EFFECTIVE DATE: April 1, 2012

LEAF: 187  
REVISION: 0  
SUPERSEDING REVISION:

---

## GENERAL INFORMATION

### 13. SERVICE CLASSIFICATION RIDERS (Continued)

#### RIDER N (Continued)

#### NET METERING FOR CUSTOMER GENERATORS

#### INTERCONNECTION AND OTHER TECHNICAL REQUIREMENTS (Continued)

- (E) (Continued)
- (4) \$5,000 for farm waste electric generating equipment;
  - (5) \$5,000 for farm wind electric generating equipment with a rated capacity greater than 25 kW and no greater than 500 kW; and
  - (6) For non-residential solar and wind electric generating equipment with a rated capacity greater than 25 kW, and no greater than 2 MW, such costs will be determined by the Company, subject to review by the Commission at the request of the customer.
- (F) Customers with wind electric generating equipment with a rated capacity of 25 kW or more shall be required to pay to the Company, prior to commencement of service under this Rider, one-half of the costs deemed necessary by the Company to permit interconnected operations with the customer, including half the cost of a second meter if required by the Company, to the extent such costs are in excess of the corresponding costs which the Company would have incurred had the customer taken service under the otherwise applicable service classification of this Rate Schedule. All such facilities will remain the property of the Company. Such interconnection costs are in addition to the cost of dedicated transformer(s) or other equipment, if required, as set forth in subparagraph (E) above.
- (G) If a customer requests to connect wind, farm waste, or non-residential solar electric generating equipment that will provide electricity to the Company, such Customer must comply with reasonable measures established by the Company to ensure the safety of the local feeder line if the total rated generating capacity of the electric generating equipment on that feeder line exceeds or will exceed 20 percent of the rated capacity of the local feeder line.

---

Issued By: William Longhi, President, Pearl River, New York