

PSC NO: 10 – Electricity
Consolidated Edison Company of New York, Inc.
Initial Effective Date: 03/19/2012
Issued in compliance with order dated 03/15/2012 in Case 09-E-0115

Leaf: 79
Revision: 1
Superseding Revision: 0

GENERAL RULES

8. Customer Use of Generating Equipment – Continued

8.3 Generating Facilities Used on an Emergency Basis for Export

The use of generating facilities at the premises for delivery to the Company's primary distribution feeders will be permitted on an emergency basis as follows: (1) when the generating equipment is operated at the direction of the NYISO under NYISO SCR procedures or EDRP procedures, or (2) at the direction of the Company under Rider O, S, or U. Delivery to the Company's secondary networks is prohibited. A Customer may not deliver to the Company's primary distribution feeders while it is receiving electric energy delivered by the Company.

A Customer operating its generating equipment on an emergency basis pursuant to this General Rule must comply with all Common Provisions of SC 11, including the Interconnection Charge and Determination of Demand, including establishment of a contract demand and installation of appropriate metering to measure the energy delivered to the Company's system. Further, such Customer is required to pay charges as would be required of Customers taking service under SC 11. The Customer will pay any costs associated with reinforcing the distribution system and/or adding facilities as may be required for load delivery.

The Company reserves the right to exclude a generator from connecting to the Company's primary distribution feeders when the Company deems it necessary to protect its system, facilities, or other Customers. In addition, the Company may prohibit a Customer from delivering power and energy to the Company's primary distribution feeders, or limit the amount of power and energy delivered, for operational reasons.

Issued by: Robert Hoglund, Senior Vice President & Chief Financial Officer, New York, NY