

PSC NO: 10 – Electricity  
Consolidated Edison Company of New York, Inc.  
Initial Effective Date: 11/01/2011

Leaf: 155  
Revision: 0  
Superseding Revision:

## GENERAL RULES

### 20. Standby Service - Continued

#### 20.2 Interconnection and Operation - Continued

##### 20.2.1 – Continued

##### (B) - Continued

- (3) The Customer's generating plant and the Company's system may be operated in parallel as required subject to the Customer's compliance with the Company's design requirements and operating rules and procedures. To accomplish such parallel operation in a safe, economical, and efficient manner, operating instructions shall be prepared by the Company, and adhered to by the authorized operating representatives of the Customer. Such operating instructions shall include, among other things, procedures for:
- (a) Maintaining proper voltage and frequency and for putting into effect voltage changes as required from time to time;
  - (b) Phasing and synchronizing the Customer's generating plant and the Company's system;
  - (c) Taking feeders out of service for maintenance or during emergency conditions and restoring them to service thereafter; and
  - (d) Controlling the flow of real power and reactive power between the Customer's generating plant and the Company's system.

Where there is to be parallel operation, the Customer's authorized operating representatives shall receive the necessary training from the Company's authorized operating representatives in the Company's operating procedures before parallel operation is begun.

Issued by: Robert N. Hoglund, Senior Vice President & Chief Financial Officer, New York, NY