

PSC NO: 10 – Electricity  
Consolidated Edison Company of New York, Inc.  
Initial Effective Date: 11/01/2011

Leaf: 247  
Revision: 0  
Superseding Revision:

## GENERAL RULES

### 24. Service Classification Riders (Available on Request) – Continued

#### RIDER R - Net Metering for Customer-Generators - Continued

##### D. Requirements for Parallel Operation

Electric generating equipment may be operated in parallel with the Con Edison system under this Rider under the following conditions:

1. The generating equipment must be designed, installed, interconnected, tested, and operated in accordance with applicable government, industry, and Company standards and must comply with the standards contained in the Standardized Interconnection Requirements.
2. The Company may install a dedicated transformer or transformers or other equipment if necessary to protect the safety or adequacy of electric service provided to other Customers. Upon the written request of the Customer, the Company will furnish within 45 days a written explanation for the Company's decision to install a dedicated transformer or other equipment. A Customer taking service under this Rider shall pay for the cost of installing such transformer or other equipment to protect the safety or adequacy of electric service provided to other Customers only up to a maximum amount, inclusive of taxes, as follows:
  - a. \$350 for solar electric generating equipment with a total rated capacity not greater than 25 kW;
  - b. \$5,000 for farm waste electric generating equipment;
  - c. \$750 for wind electric generating equipment with a total rated capacity not greater than 25 kW;
  - d. \$350 for micro-CHP generating equipment with a total rated capacity of at least 1 kW and not more than 10 kW or fuel cell electric generating equipment with a total rated capacity not greater than 10 kW;
  - e. \$5,000 for farm wind electric generating equipment with a total rated capacity greater than 25 kW and not more than 500 kW; and
  - f. the Company's actual cost for non-residential solar or non-residential wind electric generating equipment with a total rated capacity greater than 25 kW and not more than 2,000 kW.

The Customer will not unreasonably refuse the Company's request to install a dedicated transformer on the Customer's premises and will cooperate with the Company to facilitate such installation in a cost effective manner. If a dedicated transformer cannot be installed in a cost effective manner or if the dedicated transformer(s) or other equipment does not satisfactorily ameliorate the concerns prompting its installation, the Customer is responsible to implement such additional measures as required to satisfactorily ameliorate the concerns as a condition for continued service under this Rider.

Issued by: Robert N. Hoglund, Senior Vice President & Chief Financial Officer, New York, NY