

PSC NO: 10 – Electricity  
Consolidated Edison Company of New York, Inc.  
Initial Effective Date: 04/01/2012  
Issued in compliance with order dated 03/16/2012 in Case 11-E-0319

Leaf: 248  
Revision: 1  
Superseding Revision: 0

## GENERAL RULES

### 24. Service Classification Riders (Available on Request) – Continued

#### RIDER R - Net Metering for Customer-Generators - Continued

##### D. Requirements for Parallel Operation - Continued

3. Generation equipment interconnected to the Company's distribution system must be installed, interconnected, tested, and operated in accordance with applicable Company standards, which are not to be inconsistent with the Standardized Interconnection Requirements.
4. If a Customer requests to connect wind, farm waste, non-residential solar, or non-residential micro-hydro electric generating equipment that will provide electricity to the Company, such Customer must comply with reasonable measures established by the Company to ensure the safety of the local feeder line if the total rated generating capacity of the electric generating equipment on that feeder line exceeds or will exceed 20 percent of the rated capacity of the local feeder line.
5. A Customer with wind electric generating equipment will be responsible for paying half the costs of interconnection if the wind electric generating equipment has a rated capacity greater than 25 kW, including half the cost of a second meter if required by the Company.

The costs of interconnection include the costs of initial engineering evaluations, switching, metering, transmission, distribution, safety provisions, engineering, administrative costs, and any associated tax expenses incurred by the Company directly related to the installation of the facilities deemed necessary by the Company to permit interconnected operations with a Customer, to the extent such costs are in excess of the corresponding costs which the Company would have incurred had the Customer taken firm service under the Service Classification that would have otherwise been applicable to the Customer. All such facilities will remain the property of the Company. These interconnection costs are in addition to the costs set forth in paragraph 2 above.

6. The Customer will not be responsible for any other costs to the Company to interconnect its system to the Customer's generation equipment other than the costs specified hereunder and in the Standardized Interconnection Requirements.
7. The Customer must permit the Company to enter the property, without notice when necessary, in the event the Customer's generation equipment malfunctions and entry is necessary to protect the public safety or preserve system reliability.

Issued by: Robert Hoglund, Senior Vice President & Chief Financial Officer, New York, NY