

PSC NO: 10 – Electricity
Consolidated Edison Company of New York, Inc.
Initial Effective Date: 03/18/2013

Leaf: 258
Revision: 2
Superseding Revision: 1

GENERAL RULES

24. Service Classification Riders (Available on Request) - Continued

RIDER S – COMMERCIAL SYSTEM RELIEF PROGRAM - Continued

C. Applications and Term of Service - Continued

6. If a Customer or Aggregator requests to operate Electric Generating Equipment for Load Relief purposes under this Rider, the application must state generator information, including the unit's serial number, nameplate rating, manufacturer, date of manufacture, fuel type or energy source, the kW enrolled using this equipment, and identification as to whether the unit incorporates three-way catalyst emission controls (natural gas-fired rich burn), a natural gas lean-burn engine of model year vintage 2000 or newer, or a diesel-fired engine of model year vintage 2000 or newer, or whether it has a NOx emission level of no more than 2.96 lb/MWh. If the generating equipment has a NOx emission level of no more than 2.96 lb/MWh, but is not natural gas-fired rich burn generating equipment that incorporates three-way catalyst emission controls, a natural gas lean-burn engine of model year vintage 2000 or newer, or a diesel-fired engine of model year vintage 2000 or newer, written certification by a professional engineer must be attached to the application attesting to the accuracy of all generation-related information contained in the application, including the NOx emission level.

Copies of all New York State Department of Environmental Conservation ("DEC") permits must be included with the application. By applying for service under this Rider, Customers and Aggregators (on behalf of their customers) agree to permit the Company to provide information regarding the Electric Generating Equipment to the DEC for its review, subject to the DEC's agreement to keep this information confidential.

7. Participation under this Rider is permitted to participants in other programs that provide payment for capacity, such as the NYISO's Special Case Resources Program, NYPA's Peak Load Management Program, the Company's Rider P, and the Company's Rider U.
8. Customers and Aggregators must meet the metering requirements specified in section E.

Issued by: Robert Hoglund, Senior Vice President & Chief Financial Officer, New York, NY