

PSC NO: 220 ELECTRICITY
NIAGARA MOHAWK POWER CORPORATION
INITIAL EFFECTIVE DATE: FEBRUARY 26, 2010
STAMPS: Issued in Compliance with Order issued February 12, 2010 in Case No. 09-E-0819.

LEAF: 245
REVISION: 1
SUPERSEDING REVISION: 0

GENERAL INFORMATION

53. STANDARDIZED INTERCONNECTION REQUIREMENTS AND APPLICATION PROCESS FOR NEW DISTRIBUTED GENERATORS 2 MW OR LESS CONNECTED IN PARALLEL TO UTILITY DISTRIBUTION SYSTEMS (Continued)

STEP 5: Applicant Commits to the Completion of the CESIR

Prior to commencement of the CESIR, the applicant shall provide the following information to the utility:

- a complete detailed interconnection design package
- the name and phone number of the individual(s) responsible for addressing technical and contractual questions regarding the proposed system, and
- if applicable, advanced payment of the costs associated with the completion of the CESIR

The complete detailed interconnection design package shall include:

- (1) Electrical schematic drawing(s) reflecting the complete proposed system design which are easily interpreted and of a quality necessary for a full interconnection. The drawings shall show all electrical components proposed for the installation, and their connections to the existing on-site electrical system from that point to the PCC.
- (2) A complete listing of all interconnection devices proposed for use at the PCC. A set of specifications for this equipment shall be provided by the applicant upon request from the utility.
- (3) The written verification test procedure provided by the equipment manufacturer, if such procedure is required by this document.
- (4) Three (3) copies of the following information:
 - Proposed three line diagram of the generation system showing the interconnection of major electrical components within the system. Proposed equipment ratings clearly needs to indicate:
 - 1) Number, individual ratings, and type of units comprising the above rating;
 - 2) General high voltage bus configuration and relay functions;
 - 3) Proposed generator step-up transformer MVA ratings, impedances, tap settings and winding voltage ratings;
 - Electrical studies as requested by the utility to demonstrate that the design is within acceptable limits, inclusive and limited to the following: system fault, relay coordination, flicker, voltage drop, and harmonics.

STEP 6: Utility Completes the CESIR

The CESIR will consist of two parts:

- (1) a review of the impacts to the utility system associated with the interconnection of the proposed system, and
- (2) a review of the proposed system's compliance with the applicable criteria set forth below.

Issued by Thomas B. King, President, Syracuse, New York