

PSC NO: 220 ELECTRICITY  
NIAGARA MOHAWK POWER CORPORATION  
INITIAL EFFECTIVE DATE: APRIL 27, 2009

LEAF: 118  
REVISION: 0  
SUPERSEDING REVISION:

## GENERAL INFORMATION

### 25. METER: (Continued)

#### 25.2 Customer-Requested Enhanced Metering (Continued)

25.2.2.4 The Company will have all rights with Customer-owned enhanced metering as with Customer-owned billing metering, as described in Rule 25.1.1.

25.2.3 Except as otherwise provided in this Tariff, the Company will have sole responsibility for the installation, maintenance, testing, and removal of all Customer-requested enhanced meters, whether owned by the Company or by the Customer.

25.2.3.1 As provided in Rule 28.4.7, the Customer will be responsible for all costs incurred by the Company in the installation, operation and maintenance of any Customer-owned metering.

25.2.4 The Company will have sole control of all Customer-requested enhanced metering, whether owned by the Company or by the Customer.

#### 25.3 Metering Installation

25.3.1 NMPC-required billing meters may be installed on Customer's side of the point of delivery.

25.3.2 If required, Company may make minor alterations to the meter cabinets and equipment enclosures, whether Customer or Company owned, in order to install locks or other devices necessary to protect the integrity of the metering equipment.

25.3.3 Customer shall provide sufficient and readily accessible space at a location on Customer's premises in accordance with Company's standards and practices for the installation of metering equipment. Customer shall provide mounting facilities as required by Company for metering equipment, whether Company or Customer owned.

25.3.4 Company may require Customer to install his service wiring so that the meter is accessible to Company employees from the outside of Customer's building.

25.3.4.1 Meters installed in new residential dwelling units constructed after July 15, 1976, shall be installed outdoors in an accessible location whenever feasible.