

PSC No: 19 - Electricity
Rochester Gas and Electric Corporation
Initial Effective Date: December 28, 2010

Leaf No. 239
Revision: 5
Superseding Revision: 4

SERVICE CLASSIFICATION NO. 14

STANDBY SERVICE (Cont'd)

STANDBY SERVICE IS NOT APPLICABLE TO:

1a). Net Metered Solar Generating Equipment

Standby Service rates shall not apply to a customer operating solar generating equipment and taking service under General Information Section 14 or 15.

1b). Net Metered Farm Waste Generators 1000kW or Less

Standby Service will not apply to a customer taking service under General Information Section 16, Farm Waste Electric Generating System option.

1c). Net Metered Wind Generators

Standby Service rates shall not apply to a customer operating wind generating equipment and taking service under General Information Section 13.

1d). Net Metered Hybrid Generators

Standby Service rates shall not apply to a customer operating a hybrid facility and taking service under General Information Section 17.

2. Emergency Generators

Standby Service rates shall not apply to customers whose only generating units are emergency generators. For the purpose of this Service Classification, a generating unit must meet each of the following two criteria to be considered an emergency generator:

- a) The emergency generator is used exclusively for purposes of supplying electrical power to the Customer when electrical power is not available from the Company.
- b) No load is served by the emergency generator while electric service is available from the Company to the premises, except for regularly scheduled tests when the generator is required to operate under load or participation in the New York Independent System Operator's ("NYISO") Special Case Resource Program or the Emergency Demand Response Program.

Excluding residential customers, the customer must submit a one-line diagram and specification sheet on the switch for the OSG for RG&E's review and approval. In addition, the customer must enter into a letter agreement with RG&E stating that the emergency generator will not operate in parallel with the Company's system.

The customer shall maintain an operating log for each emergency generator indicating the date, time, hours, and purpose of each operation of each such facility. This log shall be made available to the Company upon request. Failure to do so will permit the Company to (a) bill the customer under this Service Classification for the amount of Standby Service which the Company can reasonably estimate was delivered to and/or available to the customer during times when the Company did not charge the customer for such service due to this emergency generator exemption; and (b) establish a Contract Demand for one year, and thereafter as applicable.

3. New York Power Authority ("NYPA") Allocations

Standby Service rates shall not apply to that portion of a customer's delivery service associated with the delivery of electricity supply pursuant to applicable NYPA programs.

ISSUED BY: James A. Lahtinen, Vice President Rates and Regulatory Economics, Rochester, New York