

PSC NO: 1 – WATER
COMPANY: Aquarion Water Company of Sea Cliff, Inc.
INITIAL EFFECTIVE DATE: DECEMBER 1, 2006

LEAF: 14
REVISION: 0
SUPERSEDING REVISION: 0

GENERAL INFORMATION

3. SERVICE PIPES AND MAINS

A. Services and Mains - The Company will furnish, place, construct, operate, maintain, and when necessary, replace at its own cost and expense, all mains, service pipes, service connections and other facilities within the territorial limits of any street, avenue, road or way that is for any highway purpose under jurisdiction of the legislative body of any city, town, village, county, or the State of New York, or other public place open to the general public for highway purposes, provided all necessary easements are furnished without cost to the Company. No service pipe will be installed by the Company within the territorial limits of a public street, as hereinbefore defined, until the service pipe and service connections from the premises to the territorial limits have been installed in a manner satisfactory to the Company.

B. Service Pipe Materials - The entire service pipe shall be copper tubing (U.S. Government specification type K soft tempered), or other pipe of a strength and quality to be approved by the Company. The minimum diameter of the service pipe shall be $\frac{3}{4}$ ". For services two inches or larger in diameter, ductile cement lined pipe of a quality equal to the American Water Works Association or Federal specifications, of weight suitable for service under the water pressure at the point where it is located shall be used.

C. Minimum Depth of Service Pipes - Minimum depth of service pipes shall be four feet six inches below the surface of the ground. Where covering over mains is less than five feet, the connection shall be made on the side of the main and service pipe shall, in no case, have less covering than the main, except where approved by the Company due to special circumstances. The Company reserves the right in all cases to stipulate the size and type of service connection to be used.

D. Inspection of Service Pipes - That portion of the service pipe without the territorial limits of any street, avenue, road or way, as hereinbefore defined, is to be approved by the Company before the trench is backfilled.

Service pipes must be located in compliance with all Sanitary regulations and, in no case, be less than ten feet (10') from any cesspool or sewerage lines unless the design is otherwise approved by the Company.

E. Existing Services - On existing services within the territorial limits as hereinbefore defined, the Company will maintain and renew when necessary the following equipment: Corporation stop; curb stop; curb box; and service pipe.

F. Separate Application for Each Premises - A separate application must be made and a separate service installed for each premises. The word "premises" as used herein shall be restricted to the following:

1. a building under one roof owned or leased by one customer, and occupied as one residence or one place of business;
2. a combination of buildings owned or leased by one customer, in one common enclosure, occupied by one family, or one corporation or firm, as a residence or place of business;

Issued by: Charles V. Firlotte, Chairman of the Board and President, 325 Prospect Ave., Sea Cliff, NY 11579-1926
(Name of Officer, Title, Address)