

PSC No: 1 – Water
UNITED WATER NEW ROCHELLE INC.
Initial Effective Date: November 1, 2006

Leaf No. 95
Revision: 0
Superseding Revision:

GENERAL INFORMATION

SERVICE CLASSIFICATION No. 3 (Continued)

6. The Customer shall install a meter pit at or near the property line of the premises and provide the necessary piping therein for the place to connect the water meter, and in addition thereto, the Customer shall furnish and install 1 lock-stop shut-off; 2-3/4" test tees; 2 double check valves with test drains, other necessary valves, and a vacuum breaker in accordance with the layout furnished by the Company, filed with the Public Service Commission of the State of New York or original Leaf No. 96.
7. A charge of \$14.22 will be made for inspecting the installation to be made by the Customer.

Issued in compliance with the Commission Order in Case 04-W-1221 dated August 24, 2005.

Issued by: M.J. Pointing, V.P. & Gen. Mgr., 225 Palmer Ave., New Rochelle, NY 10801