

PSC No: 1 – Water  
UNITED WATER NEW ROCHELLE INC.  
Initial Effective Date: November 1, 2006

Leaf No. 20  
Revision: 0  
Superseding Revision:

### **GENERAL INFORMATION**

- (f) Any repairs or maintenance necessary on the Customer's service pipe or any pipe or fixture in or upon the Customer's premises shall be performed by the Customer at his expense and risk.
- (g) The Customer shall notify the Company promptly of any leak, defect or damage affecting the service pipe between the property line and the point where metered.
- (h) The Customer shall install a stop and waste cock of a type approved by the Company on his service pipe immediately adjacent to the house side of the meter, and so located to be readily accessible to the occupants.

#### **12. PLUMBING WORK MUST BE APPROVED BY COMPANY:**

- (a) All plumbing work done on Customer's service pipes between the property line and the meter shall be submitted for the inspection of the Company, and no underground work shall be covered up until inspected and approved by the Company.

#### **13. CROSS CONNECTIONS NOT ALLOWED:**

- (a) No pipe or fixtures connected with the mains of the Company shall also be connected with pipes or fixtures supplied with water from any other source, unless specifically approved by the Department of Health of the State of New York.

#### **14. METER AND METER INSTALLATIONS:**

- (a) The Company shall have the right to determine the type and size of meter to be installed.
- (b) Meters will be furnished, installed and removed by the Company and shall remain its property.
- (c) The Customer shall provide at his expense a readily accessible and protected location for the installation of a meter at such a point as will control the entire supply to the premise, which location must be acceptable to the Company as most convenient for its service.
- (d) When the Customer's meter is not installed in a building it shall be placed in a meter box or vault of a type approved by the Company and furnished at the expense of the Customer, which box or vault, shall be placed just inside the Customer's property line or at such other location as may be approved by the Company.
- (e) Each premise shall be supplied through a separate meter or meters.

Issued in compliance with the Commission Order in Case 04-W-1221 dated August 24, 2005.

Issued by: M.J. Pointing, V.P. & Gen. Mgr., 225 Palmer Ave., New Rochelle, NY 10801