

PSC No: 1 – Water
UNITED WATER NEW ROCHELLE INC.
Initial Effective Date: November 1, 2006

Leaf No. 24
Revision: 0
Superseding Revision:

GENERAL INFORMATION

- (i) A detector check valve with by-pass shall be furnished and installed by the Customer just inside the building wall or other convenient location on the Customer's premise between any unmetered outlet connection and any general service connection.
- (j) IN PUBLIC AND PRIVATE STREETS:
 - (1) The private fire service connection from the main to the property line, including all necessary valves, shall be furnished and installed at the expense of the Company.

18. DISCONTINUANCE OF WATER SERVICE TO NONRESIDENTIAL SERVICE

- (a) Service rendered under any application, contract or agreement, may be discontinued by the Company after reasonable notice for any of the following reasons:
 - (1) For willful or indifference waste of water due to any cause.
 - (2) For failure to protect from damage the meter and connection, or for failure to protect and maintain the service pipe or fixtures on the property of the Customer in a condition satisfactory to the Company.
 - (3) For tampering with any meter, connections, service pipe, curb cock, seal or any other appliance of the Company controlling or regulating the Customer's water supply.
 - (4) For failure to provide the Company's employees free and reasonable access during normal business hours to the premises supplied, or for obstructing the way of ingress to the meter or any other appliance controlling or regulating the Customer's water supply.
 - (5) For non-payment of any account for water supplied, for water service, for meter maintenance, or for any fee or charge accruing under the contract.
 - (6) In case of vacancy of the premises.
 - (7) For violation of any rule or regulation of the Company as filed with the Public Service Commission.

Issued in compliance with the Commission Order in Case 04-W-1221 dated August 24, 2005.

Issued by: M.J. Pointing, V.P. & Gen. Mgr., 225 Palmer Ave., New Rochelle, NY 10801