

P.S.C. No. 1 – Water
United Water New York Inc.
Initial Effective Date: March 1, 2008

Leaf No. 22
Revision: 0
Superseding Revision: 0

GENERAL INFORMATION

C. The Company will maintain meters as stated insofar as ordinary wear and tear is concerned, but in case of damage by freezing, hot water, or external causes, the Customer will be held responsible for the cost of repairs.

D. Back flow of hot water which may cause damage to the meter shall be prevented by the installation of suitable equipment in accordance with the provisions of this Tariff governing cross connection control.

E. For all work and labor performed and all material furnished by the Company for resetting tampered meters, a fee in accordance with that set forth under Service Classification No. 8 (Miscellaneous Service-Resetting Tampered Meters) of this Tariff will be charged to the Customer or party requiring said service unless otherwise provided in this Tariff.

4.2 Location of Meters

A. The Customer shall provide a place acceptable to the Company for the location of the meter and any automatic meter reading equipment.

B. Meters should be installed inside buildings unless otherwise required or agreed to by the Company. They shall be placed in a clean, dry, safe place not subject to great variations in temperature, at or near the front wall, as close as possible to the point of entrance of the connecting pipe.

C. Meters should be supported firmly, not less than 12 inches nor more than 36 inches above the floor level and should be readily accessible at all reasonable times for inspection, reading, testing, changing and making necessary adjustment or repairs by employees of the Company.

D. Where the Company agrees it is necessary to set the meter outside the building, it shall be installed—at the expense of the Customer—in a pit which is water-tight and frostproof or a hot-box structure (heated, above-ground). A hot-box is required to house meters for services greater than 2" in size. When installed in a pit, the cover of the pit shall be fastened with a convenient locking device. Where the distance from the property line to the front wall of the building is greater than 75 feet, the Company may require that the meter be set at or near the property line. If the pit is to be located upon property not owned or controlled by the Customer, written consent of the owner shall be first obtained.

Issued in compliance with the Commission Order 06-W-0131 dated December 14, 2006.

Issued by: M.J. Pointing, V.P. & Gen. Mgr., 360 West Nyack Road, Nyack, NY 10994