

PSC NO: 1 ELECTRICITY  
COMPANY: VILLAGE OF FAIRPORT  
INITIAL EFFECTIVE DATE: 1/01/08

LEAF: 13  
REVISION: 0  
SUPERSEDING REVISION:

SERVICE CLASSIFICATION NO. 4 (CONT'D)

- (f) The customer shall maintain a power factor at the point of delivery of not less than 90% lagging or leading as measured on a 30 minute basis. If the customer is notified that their power factor has fallen below 90%, corrective action must be taken within ninety (90) days. If the customer fails to take corrective action within the ninety (90) days after notification, the Municipal Commission shall discontinue service under Service Classification #4 and bill service under Service Classification #3 until power factor is corrected.

Issued by: Kenneth W. Moore, Village Administrator, Fairport, N.Y