

PSC NO: 220 ELECTRICITY
NIAGARA MOHAWK POWER CORPORATION
INITIAL EFFECTIVE DATE: APRIL 27, 2009

LEAF: 112
REVISION: 0
SUPERSEDING REVISION:

GENERAL INFORMATION

23. TRANSFORMER VAULTS AND SUBSTATIONS: (Continued)

23.2 Where Company's transformers and equipment will be installed outdoors, Company will specify space requirements, transformer pads or foundations, grading, ducts and enclosures. Customer shall furnish detailed plans for approval by the Company prior to construction and shall construct, own and maintain transformer pads, foundations, ducts, site and enclosures.

23.3 Where the Company's transformers and equipment will be installed in a vault or in enclosure in or adjacent to a building, above, below or at grade, Company will specify requirements for the vault and ducts or enclosure. Customer shall furnish detailed plans for approval by Company and shall construct, own and maintain the vault or enclosure and ducts.

23.3.1 The vault shall comply with all provisions for transformer vaults stated in the latest edition of the National Electric Code and all applicable local ordinances and building codes.

23.3.2 Neither service equipment nor metering shall be located in the transformer vault.

23.3.3 Where the Company's equipment is to be located above or below grade, Customer shall provide at his expense a mutually agreed upon means for the installation, removal or replacement of Company's equipment either by elevator, permanent outdoor hoist or mobile crane.

24. SERVICE ENTRANCE AND BUILDING WIRING:

24.1 Customer shall provide the service entrance, in accordance with Company requirements, and all wiring on Customer's premises, beyond the point of delivery. The location of the service entrance and metering equipment shall be designated by Company. (Service will not be connected until Customer's wiring has been approved). Company will accept approval of Customer's wiring by company approved electrical inspection agencies that are also acceptable to the local authority exercising jurisdiction, if any.

24.2 The Company may refuse to connect service or may disconnect an existing service when in the Company's judgment or when Company has received notice that the customer's installation is not in a safe and proper operating condition. Also, when the installation does not conform with Niagara Mohawk's Specifications For Electrical Installations or the customer's equipment or use thereof impairs the Company's equipment or service to other customers.

24.3 Where Company is to supply service to individual tenants within a building, customer shall install and maintain feeders to connect each such tenant and Company will install and maintain meters on these feeders. Transformation required for other utilization voltages within the building shall be provided on the load side of the meter by the customer. All other metering shall be at the voltage of delivery of service to the building.