

PSC NO: 220 ELECTRICITY  
NIAGARA MOHAWK POWER CORPORATION  
INITIAL EFFECTIVE DATE: APRIL 27, 2009

LEAF: 70  
REVISION: 0  
SUPERSEDING REVISION:

## GENERAL INFORMATION

### 5. DISTURBANCES:

5.1 Company's service may be refused or withdrawn when Customer's wiring or equipment is so designed or operated as to disturb Company's service to other Customers.

#### 5.2 Motors:

All motors connected to Company lines (1) shall be a type that shall not require starting current deemed unreasonable by Company, or (2) shall have starting devices to restrict the starting current within the limits considered reasonable by Company, or (3) both. Motors of five horse power or less connected to Company's lines shall normally be single phase, and motors over five horse power shall normally be three phase, but Customer should contact Company in advance to ascertain the applicable condition.

5.3 Customer, in taking three phase electric service, shall maintain as nearly as is reasonably possible, equal currents in each of the three phase conductors at the point of taking. If at any time the current in any phase conductor shall exceed the average of the currents in all the three phase conductors by more than five percent (5%), the amount to be paid by Customer for the period within which the unbalance occurred may be increased by a percentage equal to that of the unbalance.

#### 5.4 Automatic Reclosing:

Where the Company has installed on its facilities equipment for automatic reclosing after an interruption of power supply, it shall be the obligation of the Customer to provide at his expense, (1) adequate protective equipment for all electrical apparatus of the Customer that might be adversely affected by the Company's reclosing equipment, and (2) such equipment as may be required for the prompt disconnection of any apparatus of the Customer that might affect proper functioning of the Company's reclosing equipment.

#### 5.5 Electrical Interferences:

If at any time, in the opinion of Company, any devices installed by Customer for purposes other than the distribution of electrical power are causing interference on the electrical system of Company, Customer or to any other person, then, upon notice from Company, it shall be the responsibility of Customer to install remedial equipment or take such other measures as may be necessary to reduce such interference to a tolerable level. Customer shall provide any facilities necessary to secure his own equipment against disturbances including but not limited to voltage pulses or harmonic frequencies, whether originating with his own equipment or elsewhere. Customer shall indemnify Company from all claims and demands against Company by any person in consequence of failure by Customer to perform his obligations under this provision.