

P.S.C. No. 1 – Water
United Water Westchester Inc.
Initial Effective Date: January 11, 2009

Leaf No. 30
Revision: 0
Superseding Revision: 0

- (c) The entire private fire service system shall be subject to the inspection, test and approval of the Company before the service is made effective. The Company, shall have the right to enter the premises at any reasonable time for the purpose of making an inspection of the entire private fire service system. Any irregularities disclosed shall be cause for discontinuing service unless corrected by the Customer within ten (10) days after written notice is given by the Company.
- (d) When the Customer requests that his general service be taken through the same line that provides private fire service, the Company may permit such joint use of its service line provided that the Customer's pipe for general service be connected to the private fire service line at a point between the main and any outlets or fixtures to be attached to such private fire service line. Such dual use of Company's service line shall be subject to the approval of the proper fire insurance inspection bureau. Immediately after the connection for general service there shall be placed a valve on the private fire service line which shall be at a convenient location for inspection by the Company. The connection for general service shall be of a size to be approved by the Company and also subject to the approval of the proper fire insurance inspection bureau. The connection for general service shall also be made at a location where a meter can be installed by the Company as close as convenient to the private fire service line. If such connection is not made inside the building the Customer shall provide suitable meter box or vault of a type and size to be approved by the Company, the meter in all instances to be set at a location where it will measure all the water used through the general service connection. The entire cost of making that part of such general service connection to a private fire service connection as is located on private property shall be borne by the Customer. Should service be discontinued by the Company for the non-payment of any bill or violation of any rule, irrespective of whether such bill or such violation relates to the general service or to the private fire service, water shall be turned off at the connection in the street and shall not be turned on again until any delinquent bills have been paid and any irregularities have been satisfactorily adjusted and the turn-on charge as specified in Section 25 has been paid.
- (e) No water shall be taken or used though a private fire service connection for any purpose other than for extinguishing accidental fires, except for the purpose of testing fire fighting equipment, or as specified under paragraph (d). Such tests as mentioned above may be made only under special permit from the Company and the Company may require that its representative be present at such test.
- (f) Hydrants and other fixtures connected with a private fire service connection may be sealed by the Company and such seals shall be broken only in case of fire or as specially permitted by the Company and the Customer must immediately notify the Company of the breaking of any such seal

Issued by: M.J. Pointing, V.P. and General Mgr., 2525 Palmer Ave., New Rochelle, NY 10801