

PSC NO: 119 ELECTRICITY
NEW YORK STATE ELECTRIC & GAS CORPORATION
Initial Effective Date: 09/01/03

Leaf: 112
Revision: 0
Superseding Revision:

GENERAL INFORMATION

9. Distributed Generation Interconnection Requirements (Cont'd.)

- F. I. Application Process for the Interconnection of New Distributed Generation Units of 300 kVA or Less, or Farm Waste Generators of 400 kW or Less, Connected to Radial Distribution Lines (Cont'd.)

B. APPLICATION PROCESS STEPS (Cont'd.)

STEP 6: Utility Completes the CESIR. (Cont'd.)

- 3) if applicable, a description of where the proposed system is not in compliance with these requirements;
- 4) except for net metering customer-generators, a good faith, detailed estimate of the total cost of completion of the interconnection of the proposed system. Such estimate will include, but not be limited to, the costs associated with any required modifications to NYSEG's system, administration, metering, and on-site verification testing. For net metering customer-generators, the estimate shall be limited to the cost of installing a dedicated transformer.

Photovoltaic, net meter, residential applicants (see Section IV: Glossary of Terms for definition) are only responsible for the costs of a dedicated transformer (see Section IV: Glossary of Terms for definition), if applicable, up to a maximum expense of \$350. Farm Waste, net meter, farm applicants are only responsible for the costs of a dedicated transformer, if applicable, up to a maximum expense of \$3,000.

STEP 7 - Applicant Commits to Utility Construction of Utility's System Modifications.

The applicant will:

- execute a standardized contract for interconnection; and
- provide NYSEG with an advance payment for NYSEG's estimated costs as identified in STEP 6, except for net metering customer-generators. (Estimated costs will be reconciled with actual costs in STEP 11.)

STEP 8 - Project Construction.

The applicant will build the facility in accordance with the NYSEG-accepted design. NYSEG will commence construction/installation of system modifications and metering requirements as identified in STEP 6. NYSEG system modifications will vary in construction time depending on the extent of work and equipment required. The schedule for this work is to be discussed with the applicant in STEP 6.

Issued by: James A. Lahtinen, Vice President – Rates & Regulatory Economics, Binghamton, NY