

PSC NO: 119 ELECTRICITY  
NEW YORK STATE ELECTRIC & GAS CORPORATION  
Initial Effective Date: 09/01/03

Leaf: 106  
Revision: 0  
Superseding Revision:

## GENERAL INFORMATION

### 9. Distributed Generation Interconnection Requirements

Applicable to any customer installing a Distributed Generation (DG) unit with a nameplate rating of 300 kVA or less, connected in parallel with NYSEG's radial distribution system (radial feeder).

These requirements are not applicable to a DG unit which is not connected to NYSEG's distribution grid. Compliance with all other tariff provisions, applicable to the Customer is required.

#### A. Definitions - The terms used herein are defined as follows:

- (1) "Contract" is defined as the document contained within the Order Denying Petitions for Rehearing, Providing Clarification, Modifying Standard Interconnection Requirements, and Directing Filing of Revised Tariffs, Case 94-E-0952, issued November 15, 2000, as the same may be revised, modified, amended, clarified, supplemented or superseded.
- (2) "Customer" is defined here as a new or existing customer of NYSEG taking service under any otherwise applicable Service Classification, who makes application to and enters into a Contract with NYSEG, to install a DG unit as defined above.
- (3) "Distributed Generation (DG)" is defined as a small generating facility, not including photovoltaics, with a nameplate rating of 300 kVA or less (aggregated on the customer side of the point of common coupling) connected in parallel with NYSEG's radial distribution system (radial feeder).
- (4) "New" with regard to DG units, is defined as those units that are installed after February 1, 2000.
- (5) "Usage" is defined as energy consumed by the Customer, not otherwise provided by the DG unit, as measured by NYSEG's meter installed at the Customer's premises.

#### B. DG Application Process:

- (1) Applications will be processed in accordance with the relevant sections of the New York State Standardized Interconnection Requirements for Distributed Generators Rated 300 kVA or Less, Connected in Parallel with Radial Distribution Lines, which is included in Section F, below. These Standard Interconnect Requirements are identical to the appendix to the Commission's Order Denying Petitions for Rehearing, Providing Clarification, Modifying Standard Interconnection Requirements, and Directing Filing of Revised Tariffs, Case 94-E-0952, issued November 15, 2000, as the same may be revised, modified, amended, clarified, supplemented or superseded, and which is incorporated herein by reference. The pertinent application steps are set forth below.
- (2) The Customer is required to make application to the Company, using a form substantially in the form of, New York State Standardized Application for Single Phase Interconnection of Distributed Generation Equipment Rated 15 kVA or Less, Connected to Parallel with the NYSEG System, or New York State Standardized Application for Interconnection Generation Equipment Rated 300 kVA or Less, Connected in Parallel with the NYSEG System, which are included in Section F herein.

Issued by: James A. Lahtinen, Vice President – Rates & Regulatory Economics, Binghamton, NY