

PSC NO: 119 ELECTRICITY
NEW YORK STATE ELECTRIC & GAS CORPORATION
Initial Effective Date: 09/01/03

Leaf: 127
Revision: 0
Superseding Revision:

GENERAL INFORMATION

9. Distributed Generation Interconnection Requirements (Cont'd.)
- F. II. Interconnection Requirements for New Distributed Generators 300 kVA or Less, or Farm Waste Generators of 400 kW or Less, Connected to Radial Distribution Lines (Cont'd.)
- b. **Three-Phase Inverters and Relays (Cont'd.)**

The voltage magnitudes listed below are given in percent of rms voltage rating of the inverter, followed in parentheses by the rms voltage magnitude for 120 V rated inverters:

Waveform 1: A three-phase sinusoidal operating at 60 Hz and 100% of rated voltage (120 V rms) interrupted by phase A voltage depressed to 49% of rated voltage (59 V rms) for six (6) cycles beginning and ending at a zero crossing while B and C phases continue at 100% of rated voltage (120 V rms). Repeat the same test with B phase depressed, with C phase depressed, with A and B phases depressed, with B and C phases depressed, and finally with all phases depressed to 49% of rated voltage (59 V rms) for six cycles.

Waveform 2: A three-phase sinusoidal operating at 60 Hz and 100% of rated voltage (120 V rms) interrupted by phase A voltage depressed to 49% of rated voltage (59 V rms) for six (6) cycles beginning and ending at a zero crossing while B and C phases are increased 125% of rated voltage (150 V rms) beginning and ending at the same point of discontinuity. Repeat the same test with B phase depressed and A and C phases increased and with C phase depressed and A and B phases increased.

Waveform 3: A three-phase sinusoidal operating at 60 Hz and 100% of rated voltage (120 V rms) interrupted by phase A voltage depressed to 88% of rated (105 V rms) for two seconds (120 cycles) beginning and ending at a zero crossing while B and C phases continue at 100% of rated voltage (120 V rms). Repeat the same test with B and C phases depressed to the same level and for the same duration holding the other two phases at 100%.

Waveform 4: A three-phase sinusoidal operating at 60 Hz and 100% of rated voltage (120 V rms) interrupted by phase A voltage increased to 111% of rated (133 V rms) for two seconds (120 cycles) beginning and ending at a zero crossing while B and C phases continue at 100% of rated voltage (120 V rms). Repeat the same test with B and C phases increased to the same level and for the same duration.

Waveform 5: A three-phase sinusoidal operating at 60 Hz and 100% of rated voltage (120 V rms) interrupted by phase A voltage increased to 138% of rated (166 V rms) for two cycles beginning and ending at a zero crossing while B and C phases continue 100% of rated voltage (120 V rms). Repeat the same test with B and C phases increased to the same level and for the same duration.

Issued by: James A. Lahtinen, Vice President – Rates & Regulatory Economics, Binghamton, NY