

PSC NO: 119 ELECTRICITY  
NEW YORK STATE ELECTRIC & GAS CORPORATION  
Initial Effective Date: 09/01/03

Leaf: 138  
Revision: 0  
Superseding Revision:

### GENERAL INFORMATION

9. Distributed Generation Interconnection Requirements (Cont'd.)

F. IV. New York State Standardized Interconnection Requirements  
Checklist for Type Testing of Distributed Generation Protection Equipment (Cont'd.)

5. Five-Minute Reconnect Test

If the device or system is capable of automatically reconnecting to the NYSEG system, following at least three test runs, was a test conducted to verify that the inverter does not automatically reconnect to the NYSEG system until after five (5) minutes of continuous normal voltage and frequency?

☐ Yes      ☐ No

If so, did the device or system reconnect to NYSEG in a time period equal to or exceeding five minutes?

☐ Yes      ☐ No

The device or system is not capable of automatically reconnecting to the NYSEG system  
( )

Issued by: James A. Lahtinen, Vice President – Rates & Regulatory Economics, Binghamton, NY