

7. Building Piping:

The company undertakes to deliver gas at such a pressure as to insure satisfactory service with reasonable pressure drops in the service lateral and house piping, but takes no responsibility for adequacy of building piping.

8. Meters:

The applicant must provide, free of charge to the company, a suitable location for the company's meter and equipment which shall be readily accessible and reasonably protected.

The meter will not be installed by the company where the piping connection is less than three-quarters of an inch.

Meter locations must be readily convenient and accessible and must be as close as possible to where the "service line" enters through the outer wall. They shall be approved by the company in every case and shall be such as to offer adequate protection to company equipment.

The consumer shall be responsible for the protection of the meters and other company property located on the premises and shall exercise reasonable care to prevent theft of, damage to, or interference with such equipment.

Only one meter will be installed by the company for each service line, except where individual metering is needed for billing purposes to the several applicants or where accuracy of measurement requires, in the company's opinion, more than one meter.

9. Installing Meter and Supplying Service:

Gas will not be connected until the applicant has satisfactorily complied with all other requirements, and the following conditions:

- (a) Settlement of prior indebtedness due the company may be required.
- (b) Gas piping within the building must be safe and adequate for the service desired, and must comply with the company's general requirements and/or requirements of public authorities having jurisdiction.