

PSC No: 19 - Electricity
Rochester Gas and Electric Corporation
Initial Effective Date: June 1, 2003
Issued under the authority of the PSC in Case 03-E-0633, order effective May 23, 2003

Leaf No. 144
Revision: 1
Superseding Revision: 0

GENERAL INFORMATION

10. DISTRIBUTED GENERATION INTERCONNECTION REQUIREMENTS (Cont'd)

If so is the procedure acceptable to demonstrate the functionality of the protective device or system?

☐ Yes ☐ No

Were all sources of power, including batteries, that are included in the system disconnected?

☐ Yes ☐ No

3. Non-Volatile Memory Test

If the device or system has a DC power supply, was it disconnected from its power supply to verify that the system has a non-volatile memory and that protection settings are not lost?

☐ Yes ☐ No

The device or system does not rely on a DC power supply to retain the protection settings. ☐

4a. Voltage and Frequency Waveform Tests – Single Phase Inverters

Has the device or system been tested with Waveforms 1 through 6 as listed in the SIR?

☐ Yes ☐ No

If so, did the device or system perform as required by these waveform tests?

☐ Yes ☐ No

Were the test voltages applied phase to ground?

☐ Yes ☐ No

Were the waveform tests repeated ten times?

☐ Yes ☐ No

4b. Voltage and Frequency Waveform Tests – Three-Phase Inverters

Has the device or system been tested with Waveforms 1 through 9 as listed in the SIR?

☐ Yes ☐ No

If so, did the device or system perform as required by these waveform tests?

☐ Yes ☐ No

ISSUED BY: James A. Lahtinen, Vice President Rates and Regulatory Economics, Rochester, New York