

PSC No: 20 - Electricity  
Rochester Gas and Electric Corporation  
Initial Effective Date: June 1, 2003

Leaf No. 162  
Revision: 0  
Superseding Revision:

**GENERAL INFORMATION****14. DISTRIBUTED GENERATION INTERCONNECTION REQUIREMENTS (cont'd)****For Synchronous Machines:**

Submit copies of the Saturation Curve and the Vee Curve

( ) Salient ( ) Non-Salient

Torque: \_\_\_\_\_ lb-ft Rated RPM: \_\_\_\_\_

Field Amperes: \_\_\_\_\_ at rated generator voltage and current  
and \_\_\_\_\_ % PF over-excited

Type of Exciter: \_\_\_\_\_

Output Power of Exciter: \_\_\_\_\_

Type of Voltage Regulator: \_\_\_\_\_

Direct-axis Synchronous Reactance (Xd) \_\_\_\_\_ ohms

Direct-axis Transient Reactance (X'd) \_\_\_\_\_ ohms

Direct-axis Sub-transient Reactance (X''d) \_\_\_\_\_ ohms

**For Induction Machines:**

Rotor Resistance (Rr) \_\_\_\_\_ ohms Exciting Current \_\_\_\_\_ Amps

Rotor Reactance (Xr) \_\_\_\_\_ ohms Reactive Power Required:

Magnetizing Reactance (Xm) \_\_\_\_\_ ohms \_\_\_\_\_ VARs (No Load)

Stator Resistance (Rs) \_\_\_\_\_ ohms \_\_\_\_\_ VARs (Full Load)

Stator Reactance (Xs) \_\_\_\_\_ ohms

Short Circuit Reactance (X''d) \_\_\_\_\_ ohms Phases:

Frame Size: \_\_\_\_\_ Design Letter: \_\_\_\_\_ ( ) Single

Temp. Rise: \_\_\_\_\_ OC. ( ) Three-Phase

**For Inverters:**

Manufacturer: \_\_\_\_\_ Model: \_\_\_\_\_

Type: ( ) Forced Commutated ( ) Line Commutated

Rated Output: \_\_\_\_\_ Amps \_\_\_\_\_ Volts

Efficiency: \_\_\_\_\_ %

**Signature:**


---

CUSTOMER SIGNATURE

TITLE

DATE

ISSUED BY: James A. Lahtinen, Vice President Rates and Regulatory Economics, Rochester, New York