

PSC No: 20 - Electricity  
Rochester Gas and Electric Corporation  
Initial Effective Date: June 1, 2003

Leaf No. 104  
Revision: 0  
Superseding Revision:

## GENERAL INFORMATION

### PART II - RULES AND REGULATIONS

#### 10. STREET LIGHTING (Cont'd)

#### **D. EXTENSION AND MAINTENANCE OF DISTRIBUTION PROVIDER FACILITIES (Cont'd)**

##### **(3) Distribution Customer Obligations - Street Lighting (Cont'd)**

- (ii) For underground supplied fixtures fed from the Distribution Provider's overhead distribution facilities, install an approved 10' riser, to be located by the Distribution Provider, on the pole, provide sufficient supply conductors coiled at top of the riser to reach the Distribution Provider's secondary facilities, install an in-line disconnecting device and, if a metallic riser is installed, provide appropriate grounds. The Distribution Provider will place the supply conductors above the riser and make connections to the distribution facilities.
- (iii) For underground supplied fixtures fed from the Distribution Provider's underground distribution facilities, build a pull box within 50' of the Distribution Provider's manhole or handhole designated as the point of service, extend a conduit from the Retail Customer's pull box to the Distribution Provider's manhole or handhole, mount the in-line disconnecting device in the pull box and leave sufficient supply conductors (cable) coiled in pull box to reach center of the Distribution Provider's manhole. In addition, the Distribution Customer shall install a 200 lb. nylon pull cord in conduit section so that the Distribution Provider can draw in the cable. If the Distribution Customer elects to install an approved direct buried cable, the cable should be left coiled and protected at the outside wall of the Distribution Provider's manhole or handhole. The Distribution Provider will locate the point of entry for the Distribution Customer and provide entry into the manhole and make all connections.

If a Retail Customer elects to feed a single fixture which is within fifty (50) feet of the Distribution Provider's manhole or handhole, the Retail Customer's pull box may be eliminated provided that there is adequate space in the pole base to mount the in-line disconnecting device and coil cable sufficient to reach the Distribution Provider's manhole or handhole.

- (f) Pay \$181.00 for each electrical point of connection of the Retail Customer's underground facilities to the Distribution Provider's overhead or underground facilities, and where it is necessary for the Distribution Provider to break a handhole or manhole wall, install a conduit stub and related material, the Distribution Customer shall pay an additional charge of \$141.00.

Subsequent reconnections and disconnections including any pursuant to Rule 10.D.1.(b), Rule 10.D.1.(e), or Special Provision 9 of Service Classification No. 1 of Schedule B, shall be at the charges shown above; however, a disconnection and reconnection at a particular location which can be performed by the Distribution Customer in a single operation will be billed only as a reconnection.

ISSUED BY: James A. Lahtinen, Vice President Rates and Regulatory Economics, Rochester, New York