

PSC No: 20 - Electricity
Rochester Gas and Electric Corporation
Initial Effective Date: June 1, 2003

Leaf No. 60
Revision: 0
Superseding Revision:

GENERAL INFORMATION

PART II - RULES AND REGULATIONS

6. EXTENSION AND MAINTENANCE OF DISTRIBUTION PROVIDER FACILITIES (Cont'd)

C. PERMANENT SERVICE LATERALS (Cont'd)

The installation of a service lateral by a Distribution Customer shall be approved by the New York Board of Fire Underwriters, Middle Department Inspection Agency or any legally constituted authority having jurisdiction in that municipality prior to the energization of such lateral by the Distribution Provider. If the premises served by the service lateral has been vacant or its account inactive for 6 months or more (except for seasonal accounts), or if the service lateral or service entrance has been damaged, the Distribution Provider reserves the right to require that the service lateral be inspected prior to being re-energized.

The Distribution Provider reserves the right to designate the service connection point of the service lateral to the Retail Customer's wiring, the connection point to the distribution system, the location of any appurtenant facilities, and the path of any portion of the service lateral installed by the Distribution Provider.

All service to Retail Customer's premises, location, or building shall be rendered through a single service lateral, except:

- (i) When two or more service connections are necessary to provide service at the least expense to the Distribution Provider or in order to render proper and reliable service without undue interruptions.
- (ii) When a Distribution Customer requests or requires the installation of two or more services to a single premise, location, or building, the Distribution Customer shall bear the costs and expenses for the additional services.

(Continued on next leaf)

ISSUED BY: James A. Lahtinen, Vice President Rates and Regulatory Economics, Rochester, New York