

PSC No: 19 - Electricity
Rochester Gas and Electric Corporation
Initial Effective Date: December 31, 2004
Issued under the authority of the PSC in Case No. 02-E-1282, issued and effective November 17, 2004.

Leaf No. 120
Revision: 2
Superseding Revision: 1

10. DISTRIBUTED GENERATION INTERCONNECTION REQUIREMENTS

Applicable to any customer installing a Distributed Generation (DG) unit with a nameplate rating of 2 MW or less, or Farm Waste Generator rated 400 kW or less, connected in parallel with RG&E's utility distribution system.

These requirements are not applicable to a DG unit which is not connected to RG&E's distribution grid. Compliance with all other tariff provisions applicable to the Customer is required.

The Standardize Interconnection Requirements (SIR), including the standard applications and contracts, are set forth in the SIR Addendum to this tariff.

ISSUED BY: James A. Lahtinen, Vice President Rates and Regulatory Economics, Rochester, New York