

PSC NO.: 2 ELECTRICITY

LEAF: 13

COMPANY: ILION BOARD OF LIGHT COMMISSIONERS

REVISION: 0

INITIAL EFFECTIVE DATE: 3/1/2005

SUPERSEDING REVISION: ____

SERVICE CLASSIFICATION NO. 3 (CONT'D)

SPECIAL PROVISIONS (CONT'D):

F. Primary and Secondary Voltage Service (Cont'd)

3. Where an overhead secondary voltage service greater than 400 amps to non-residential Customers is supplied, the Customer, from the metered point of service entrance, at his or her own expense and in a manner satisfactory to the Utility, shall furnish, install and maintain such switches, transformers, regulators, capacitors and other equipment as the Utility may deem necessary to assure stability and compatibility with the system service.

4. Where an underground secondary voltage service greater than 400 amps to non-residential Customers is supplied, the Customer shall furnish, install and maintain all electrical equipment such as all wire switches, transformer, regulators, capacitors and other required equipment as the Utility may deem necessary to assure stability and compatibility with the system service to the point of connection on the Utility's electric system.

Issued by: Kevin J. Manfreda, Superintendent, Municipal Building, Ilion, NY 13357