

PSC NO: 119 ELECTRICITY
NEW YORK STATE ELECTRIC & GAS CORPORATION
Initial Effective Date: 01/01/04

Leaf: 107
Revision: 1
Superseding Revision: 0

GENERAL INFORMATION

9. Distributed Generation Interconnection Requirements (Cont'd.)

C. DG Standardized Contract:

- (1) Customer is required to enter into a signed Contract with NYSEG substantially in the form of, New York State Standardized Contract for Interconnection of New Distributed Generators with Capacity of 300 kVA or less, or Farm Waste Generators of 400 kW or Less, to be Operated in Parallel, which is included in Section F.V. below.
- (2) Termination of the Contract by either party will be in accordance with the Contract section 1.2 Termination.

D. DG Interconnection Requirements:

- (1) DG Interconnection Requirements will be in accordance with the relevant sections of NYSEG's Requirements for Independent Power Producers of Electricity pertaining to the NYSIRs.

E. DG Customer Charges:

- (1) For units over 15 kVA, a \$350 application fee will be required to be paid with the completed application.
- (2) For units of 15 kVA and less, no application fee is required.
- (3) For all units 300 kVA and less, excluding residential photovoltaic systems rated 10 kW or less and Farm Waste Generators, the Customer will be responsible for an advance payment for NYSEG's estimated costs associated with engineering review, system modifications, metering, and on-site verification.
- (4) The Application fee, if required, and any advance payment will be applied against NYSEG's total cost of interconnection which will be reconciled after final acceptance of the unit. The Customer will receive either a bill for any balance due or a reimbursement for overpayment as determined by the Company's reconciliation.

Issued in Compliance with order in Case Nos. 02-E-1654 and 02-E-1282 dated 03/20/03.

Issued by: James A. Lahtinen, Vice President – Rates & Regulatory Economics, Binghamton, NY