

PSC NO: 119 ELECTRICITY  
NEW YORK STATE ELECTRIC & GAS CORPORATION  
Initial Effective Date: 01/01/04

Leaf: 106  
Revision: 1  
Superseding Revision: 0

## GENERAL INFORMATION

### 9. Distributed Generation Interconnection Requirements

Applicable to any customer installing a Distributed Generation (DG) unit with a nameplate rating of 300 kVA or less, or Farm Waste Generator rated 400 kW or less, connected in parallel with NYSEG's radial distribution system (radial feeder).

These requirements are not applicable to a DG unit which is not connected to NYSEG's distribution grid. Compliance with all other tariff provisions, applicable to the Customer is required.

#### A. Definitions - The terms used herein are defined as follows:

- (1) "Contract" is defined as the document contained within the New York State Standard Interconnection Requirements and Application Process for New Distributed Generators, 300 kVA or Less, or Farm Waste Generators 400 kW or Less, Connected in Parallel with Radial Distribution Lines, posted on the NY PSC website at [www.dps.state.ny.us/distgen.htm](http://www.dps.state.ny.us/distgen.htm), as the same may be revised, modified, amended, clarified, supplemented or superseded.
- (2) "Customer" is defined here as a new or existing customer of NYSEG taking service under any otherwise applicable Service Classification, who makes application to and enters into a Contract with NYSEG, to install a DG unit as defined herein.
- (3) "Distributed Generation (DG)" is defined as a small generating facility, with a nameplate rating of 300 kVA or less, or Farm Waste Generators with a nameplate rating of 400 kW or less, (aggregated on the customer side of the point of common coupling) connected in parallel with NYSEG's radial distribution system (radial feeder).
- (4) "New" with regard to DG units, is defined as those units that are installed after February 1, 2000.
- (5) "Usage" is defined as energy consumed by the Customer, not otherwise provided by the DG unit, as measured by NYSEG's meter installed at the Customer's premises.
- (6) "NYSIRs" is defined as the New York State Standard Interconnection Requirements and Application Process for New Distributed Generators 300 kVA or Less, or Farm Waste Generators 400 kW or Less, Connected in Parallel with Radial Distribution Lines, as the same may be revised, modified, amended, clarified, supplemented or superseded, as posted on the NY PSC website at [www.dps.state.ny.us/distgen.htm](http://www.dps.state.ny.us/distgen.htm).

#### B. DG Application Process:

- (1) Applications will be processed in accordance with the relevant sections of the NYSIRs, which are incorporated herein by reference. The pertinent application steps are set forth below.
- (2) The Customer is required to make application to the Company, using the form(s) provided in the NYSIRs, which are included in Section F herein.

Issued in Compliance with order in Case Nos. 02-E-1654 and 02-E-1282 dated 03/20/03.

Issued by: James A. Lahtinen, Vice President – Rates & Regulatory Economics, Binghamton, NY