

PSC NO: 15 ELECTRICITY LEAF: 167.3  
COMPANY: CENTRAL HUDSON GAS & ELECTRIC CORPORATION REVISION: 0  
INITIAL EFFECTIVE DATE: 09/30/05 SUPERSEDING REVISION:

SERVICE CLASSIFICATION NO. 1 (Cont'd)

RESIDENTIAL SERVICE (Cont'd)

SPECIAL PROVISIONS (Cont'd)

- 1.6 Wind Electric Generation - Customers that own or operate wind electric generating equipment, as defined in Public Service Law Section 66-1, with a rated capacity of not more than 25 kW for residential wind generation and a rated capacity of not more than 125 kW for farm service wind generation may supply their electric load and/or sell electric energy to the Company as set forth in General Information Section 3.C. Total residential and farm service wind electric generation load on Central Hudson's system may not exceed 2.2 MW.

Customers must enter into a Standardized Contract for Interconnection of New Distributed Generation Units with Central Hudson, pursuant to General Information Section 3.C and in compliance with Public Service Law Section 66-1, in order to take service under this Special Provision. The customer shall be responsible for payment of one-half of the expense of the interconnection on wind-electric generating equipment with a rated capacity of more than 10 kW.

Customers with wind electric generating equipment will be required to pay Central Hudson's actual costs of installation for a dedicated transformer, or transformers, should it be determined to be necessary. For a customer with wind electric generating equipment with a combined rated capacity of not more than 25 kW that is located and used at the customer's residence such installation costs shall not exceed \$750. For a customer with wind electric generating equipment with a combined rated capacity of not more than 125 kW that is located and used at the customer's residence such installation costs shall not exceed \$1,000.

In the event that the total rated generating capacity of electric generating equipment that provides electricity to the Company through the same local feeder line exceeds twenty percent of the rated capacity of the local feeder line, the customer owning or operating such equipment may be required to comply with additional measures to ensure the safety of the local feeder line. Wiring and switches of these facilities may be arranged in parallel so as to permit the flow of current from the customer to the Company and vice versa.

Issued by: Arthur R. Upright, Senior Vice President, Poughkeepsie, New York