

PSC NO: 15 ELECTRICITY
COMPANY: CENTRAL HUDSON GAS & ELECTRIC CORPORATION
INITIAL EFFECTIVE DATE: 04/01/05

LEAF: 48
REVISION: 1
SUPERSEDING REVISION: 0

7. SERVICE LATERALS FROM UNDERGROUND ELECTRIC LINES

Where electric lines are installed underground the portion of the underground service lateral within the property line shall be installed at the applicant's or customer's expense in accordance with the Company's specifications by an electrical contractor or other qualified person selected by the applicant or customer and shall be owned and maintained by the applicant or customer.

Underground service laterals from the Company's underground network system adjacent to the applicant's or customer's premises will be installed by the Company on payment by the applicant or customer of the estimated construction cost of the portion within the property subject to tariff provisions for the 100 foot allowances in cases of required undergrounding.

Where underground lines are installed to replace overhead lines the customer shall do the necessary rewiring of his premises at his expense to connect to an underground service lateral.

The points of connection of the service lateral to the Company's electric lines and to the applicant's or customer's building shall be determined in all cases by the Company.

All service laterals shall be installed in the manner provided in the company's "Specifications and Requirements for Electric Installations" which is available for inspection at the Company's offices.

Issued by: Arthur R. Upright, Senior Vice President, Poughkeepsie, New York