

PSC No. 1 - Water  
United Water South County Water Inc.  
Initial Effective Date: 06/01/05

Leaf No. 45  
Revision: 0  
Superseding Revision: 0

## GENERAL INFORMATION

### VII. METERED SERVICE (cont'd.)

#### F. Testing of Meters (cont'd.)

In the event that the meter is found to over-register in excess of 4% at any flow within the normal test flow limits, the fee will be returned to the customer; otherwise it will be retained. Adjustments in bills for over-registration of the meter will be made in accordance with the current rules of the public Service Commission.

### VIII. GENERAL RULES

#### A. Hydrants - Public or Private

No person shall open or interfere or draw water from any unmetered fire hydrant without permission from the Company, chiefs of the fire department or their authorized assistants.

#### B. Sprinkling

The charge for water service under Service classification No. 1 or No. 2 includes the use of water for sprinkling. There may be times when, in the opinion of the Company, it may be necessary to restrict the use of this service to certain definite periods or to prohibit it entirely. In this event all customers will be notified.

#### C. Frost Provision

Extension of pipe line facilities are not normally made when the ground in which such pipes and connections are required to be laid shall be frozen or shall otherwise present serious obstacles to laying the same.

#### D. Cross Connection Control

The following provisions are intended to implement the Company's general right to protect its water supply from contamination, and more specifically, to implement the cross connection control responsibilities imposed on the Company by the Public Health Law and the State Sanitary Code. A cross connection means a physical connection through which a water supply could be contaminated via the intrusion of a contaminant from the customer's premises as a result of backflow. Backflow is a reversal in the normal or intended flow of water because of a differential in pressure that causes the flow of water into the distribution system from any source other than its intended source.

Issued in compliance with order in Case 02-W-0949 dated 05/21/2004

Issued by: Robert J. Iacullo, President, 360 West Nyack Rd., West Nyack, NY 10994