

..DID: 13285

..TXT: PSC NO: 12 GAS

LEAF: 202

COMPANY: THE BROOKLYN UNION GAS COMPANY

REVISION: 3

INITIAL EFFECTIVE DATE: 10/01/00

SUPERSEDING REVISION: 2

STAMPS: Issued in compliance with order in Case 00-G-0996 dated August 24, 200

RECEIVED: 09/29/00 STATUS: Effective EFFECTIVE: 10/01/00

SERVICE CLASSIFICATION No. 6C - Continued

The "outside temperature" for the purposes of this Service Classification shall be the temperature as measured outside of the customer's premises except that, if such information is not readily and accurately available, the Company shall be entitled to utilize the temperature measured at The Central Park Observatory.

- c. The consumer shall install and maintain at all times a sufficient standby alternate fuel supply and the dual-fuel equipment necessary to utilize same in the event that transfer of fuel sources is required pursuant to paragraph b, above. The temperature settings of the control devices, whether automatic or semi-automatic, are to be established solely by the Company.

Unless otherwise expressly authorized by the Company in writing, a supply of alternate fuel sufficient to meet the consumer's fuel consumption needs for a period of ten (10) days at the beginning of the heating season shall be the minimum adequate standby alternate fuel supply hereunder.

Such dual-fuel equipment and all associated control devices, the installation and the subsequent operation thereof shall be subject to the approval of the Company.

Whenever the Company becomes aware that the Consumer's equipment is incapable of switching over to an alternate fuel and/or that the Consumer does not have a reasonable amount of fuel on hand considering the time in the heating season (at times other than a Company called interruption), the Company shall notify the Consumer that the violation must be corrected within ten (10) business days. This requirement is for Customers whose alternate fuel is distillate and non-distillate in the case of human needs Customers. It shall be the responsibility of the Consumer to contact the Company and provide proof that the violation has been corrected. However, this will not apply if the Customer stipulates in writing that the Customer is willing and able to shut down during periods of interruption.

Issued by: Steven L. Zelkowitz, Sr. Vice President and General Counsel, Brooklyn, NY