

..DID: 10792
..TXT: PSC NO: 15 ELECTRICITY LEAF: 192
COMPANY: CENTRAL HUDSON GAS & ELECTRIC CORPORATION REVISION: 0
INITIAL EFFECTIVE DATE: 02/01/00 SUPERSEDING REVISION:
STAMPS:
Cancelled by 1 Rev. Leaf No. 192 Effective 05/01/2001
RECEIVED: 12/01/99 STATUS: Cancelled EFFECTIVE: 02/01/00

SERVICE CLASSIFICATION NO. 3 (Cont'd)

LARGE POWER PRIMARY SERVICE (Cont'd)

SPECIAL PROVISIONS (Cont'd)

3.3 CURTAILABLE ELECTRIC SERVICE (Cont'd)

- h) Any customer taking service under this Special Provision shall be permitted to operate emergency generating equipment during a curtailment period to reduce the load to a level below the Firm Power Level, as defined above. The customer and the Company shall agree upon the operating mode, interconnection and equipment specifications as described in Central Hudson's Installation Guide for Customer Owned Generators.
- i) The Company reserves the right to discontinue availability of this Special Provision to any customer whose curtailment performance is unsatisfactory, in the sole judgement of the Company. Performance will be determined to be unsatisfactory if the customer's rate of compliance with notice of curtailment is less than 50% for two consecutive Peak Seasons in which that customer has participated in this Special Provision. The compliance level for each curtailment period shall be defined as the difference between the maximum monthly billing demand and the maximum demand within the curtailment period divided by the difference between the maximum monthly billing demand and the Firm Power Level.
- The result above shall be expressed as a percentage. All maximum Kw. values shall be determined on a 15 minute integrated basis.
- j) Once this Special Provision is elected, service must be taken under this Special Provision for one calendar year.

Issued by: Arthur R. Upright, Senior Vice President, Poughkeepsie, New York