

..DID: 9630

..TXT: PSC NO: 5 WATER

LEAF: 7

COMPANY: THE CALLICOON WATER COMPANY

REVISION: 0

INITIAL EFFECTIVE DATE: 11/01/99

SUPERSEDING REVISION:

STAMPS:

Effective date postponed to 03/01/00. See Supplement No. 1

RECEIVED: 08/16/99 STATUS: Effective EFFECTIVE: 03/01/00

GENERAL INFORMATION

- L. The company will supply water in the distribution system at pressures between 20 and 100 pounds per square inch (psi) and will strive, where practicable, to maintain a normal working pressure of 60 psi with a minimum of 35 psi. If the company makes changes to its system which cause the pressure to increase to over 100 psi to existing customers, the company will be responsible for the first installation of the necessary equipment in the customer's premises. From that point on the equipment will be considered part of the customer's internal plumbing and the customer will be responsible for its maintenance or replacement. If a water pressure reducing valve, in the customer's or applicant's opinion, is necessary or desired to safeguard the plumbing, it is the customer's or applicant's responsibility to purchase, install and maintain this equipment. Where a pressure reducing valve is used it is also advisable to install a suitable pressure relief valve. All installations will comply with the local building codes and standards and are considered a part of the customer's internal plumbing.
- M. Failure in Supply. The company undertakes to use reasonable care and diligence to provide a constant supply of water at a reasonable pressure but reserves the right, at any time, after due notice (unless an emergency occurs), to shut off the water in its mains for the purpose of making repairs and extensions.
- N. Frost protection. Extensions of pipe line facilities are not normally made when the ground, in which such pipes and connections are required to be laid, shall be frozen or shall otherwise present serious obstacles to laying the same.

Issued By: Craig Stewart, Secretary, PO Box 277, Callicoon, NY 12723

(Name of Officer, Title, Address)