

..DID: 3685

..TXT: PSC NO: 12 GAS

LEAF: 211

COMPANY: THE BROOKLYN UNION GAS COMPANY

REVISION: 0

INITIAL EFFECTIVE DATE: 10/01/98

SUPERSEDING REVISION:

STAMPS:

Cancelled by 1 Rev. Leaf No. 211 Effective 10/01/1998

RECEIVED: 06/01/98 STATUS: Cancelled EFFECTIVE: 10/01/98

SERVICE CLASSIFICATION No. 6G - Continued

- b. It is understood and agreed that as a condition of service hereunder consumers shall be required to transfer their fuel supply from gas to an alternate fuel source whenever the outside temperature falls below the temperature specified by the Company.

Unless otherwise expressly authorized by the Company in writing, the "alternate fuel" hereunder shall be No. 2 fuel oil.

The "outside temperature" for the purposes of this Service Classification shall be the temperature as measured outside of the customer's premises except that, if such information is not readily and accurately available, the Company shall be entitled to utilize the temperature measured at The Central Park Observatory.

- c. The consumer shall install and maintain at all times a sufficient standby alternate fuel supply and the dual-fuel equipment necessary to utilize same in the event that transfer of fuel sources is required pursuant to paragraph b, above. The temperature settings of the control devices, whether automatic or semi-automatic, are to be established solely by the Company.

Unless otherwise expressly authorized by the Company in writing, a supply of alternate fuel sufficient to meet the consumer's fuel consumption needs for a period of ten (10) days shall be the minimum adequate standby alternate fuel supply hereunder.

Such dual-fuel equipment and all associated control devices, the installation and the subsequent operation thereof shall be subject to the approval of the Company.

Issued by: Robert J. Fani, Senior Vice President, Brooklyn, New York