

..DID: 2744

..TXT: PSC NO: 1 ELECTRICITY LEAF: 87

COMPANY: NEW YORK MUNICIPAL POWER AGENCY REVISION: 0

INITIAL EFFECTIVE DATE: 05/01/98 SUPERSEDING REVISION:

STAMPS:

Cancelled by 1 Rev. Leaf No. 87 Effective 12/01/1998

RECEIVED: 03/27/98 STATUS: Cancelled EFFECTIVE: 05/01/98

GENERAL INFORMATION (CONT'D)

This evidence shall be an approval from the New York Board of Fire Underwriters and/or any legally constituted authority having jurisdiction. If additional wiring or equipment is installed on such premises, the customer shall notify the Utility, before connection to the Utility's service, and secure approval as indicated above.

B. Outdoor Meters

The Utility may require an applicant for service to install his or her service wiring so that the meter is accessible to the Utility's employees from the outside of the applicant's building. The cost of installation of facilities to accept an outdoor meter, or to relocate an existing non-accessible meter, shall be borne by the customer.

C. Primary Voltage Service

Where a primary voltage service (4,160 volts; 34,500 volts) is supplied, the customer, from the metered point of the service entrance, at his own expense, and in a manner satisfactory to the Utility, shall furnish, install, and maintain such switches, transformers, regulators, capacitors, and other equipment as the Utility may deem necessary to assure stability and compatibility with the system service.

D. Utility Property

1. The applicant shall exercise reasonable precautions to protect the utility's property on the premises, and may be liable to the utility in the case of loss or damage caused by negligence of the customer or his or her employee.

Issued by: New York Municipal Power Agency