

..DID: 14351
..TXT: PSC NO: 15 ELECTRICITY LEAF: 19.11
COMPANY: CENTRAL HUDSON GAS & ELECTRIC CORPORATION REVISION: 0
INITIAL EFFECTIVE DATE: 12/29/00 SUPERSEDING REVISION:
STAMPS: Issued in Compliance with Order in C. 94-E-0952 dated November 15, 200
Cancelled by 1 Rev. Leaf No. 19.11 Effective 01/24/2002
RECEIVED: 12/28/00 STATUS: Cancelled EFFECTIVE: 12/29/00

3. APPLICATION FOR SERVICE (cont'd)

C. Distributed Generation Interconnection Requirements (cont'd)

H. NEW YORK STATE STANDARDIZED CONTRACT FOR INTERCONNECTION OF NEW DISTRIBUTED GENERATION UNITS WITH CAPACITY OF 300 kVA OR LESS TO BE OPERATED IN PARALLEL (cont'd)

III. INSTALLATION, OPERATION AND MAINTENANCE OF UNIT (cont'd)

- 3.3 Observation of the Unit - Fourteen-day Period: The Company may conduct on-site verifications of the Unit and observe the performance of verification testing within a reasonable period of time, not exceeding fourteen days, after receiving a written request from the Customer to begin producing energy in parallel with the Company's system. The Company may accept or reject the request, consistent with the SIR, based upon the verification test results.
- 3.4 Observation of the Unit - Post-Fourteen-day Period: If the Company does not perform an on-site verification of the Unit and observe the performance of verification testing within the fourteen-day period, the Customer may begin to produce energy after certifying to the Company that the Unit has been tested in accordance with the verification testing requirements of the SIR and has successfully completed such tests. After receiving the certification, the Company may conduct an on-site verification of the Unit and make reasonable inquiries of the Customer, but only for purposes of determining whether the verification tests were properly performed. The Customer shall not be required to perform the verification tests a second time, unless irregularities appear in the verification test report or there are other objective indications that the tests were not properly performed in the first instance.
- 3.5 Observation of the Unit - Operations: The Company may conduct on-site verification of the operations of the Unit after it commences operations if the Company has a reasonable basis for doing so based on its responsibility to provide continuous and reliable utility service or as authorized by the provisions of the Company's Retail Tariff relating to the verification of customer installations generally.

Issued by: Arthur R. Upright, Senior Vice President, Poughkeepsie, New York