

..DID: 14352
..TXT: PSC NO: 15 ELECTRICITY LEAF: 19.12
COMPANY: CENTRAL HUDSON GAS & ELECTRIC CORPORATION REVISION: 0
INITIAL EFFECTIVE DATE: 12/29/00 SUPERSEDING REVISION:
STAMPS: Issued in Compliance with Order in C. 94-E-0952 dated November 15, 200
Cancelled by 1 Rev. Leaf No. 19.12 Effective 01/24/2002
RECEIVED: 12/28/00 STATUS: Cancelled EFFECTIVE: 12/29/00

3. APPLICATION FOR SERVICE (cont'd)

C. Distributed Generation Interconnection Requirements (cont'd)

H. NEW YORK STATE STANDARDIZED CONTRACT FOR INTERCONNECTION OF
NEW DISTRIBUTED GENERATION UNITS WITH CAPACITY
OF 300 KVA OR LESS TO BE OPERATED IN PARALLEL (cont'd)

III. INSTALLATION, OPERATION AND MAINTENANCE OF UNIT (cont'd)

3.6 Costs of Dedicated Facilities: During the term of this Agreement, the Company shall design, construct and install the Dedicated Facilities. The Customer shall be responsible for paying the incremental capital cost of such Dedicated Facilities attributable to the Customer's Unit. All costs associated with the operation and maintenance of the Dedicated Facilities after the Unit first produces energy shall be the responsibility of the Company.

IV. DISCONNECTION OF THE UNIT

4.1 Emergency Disconnection: The Company may disconnect the Unit, without prior notice to the Customer (a) to eliminate conditions that constitute a potential hazard to Company personnel or the general public; (b) if pre-emergency or emergency conditions exist on the Company system; (c) if a hazardous condition relating to the Unit is observed by a utility inspection; or (d) if the Customer has tampered with any protective device. The Company shall notify the Customer of the emergency if circumstances permit.

4.2 Non-Emergency Disconnection: The Company may disconnect the Unit, after notice to the responsible party has been provided and a reasonable time to correct, consistent with the conditions, has elapsed, if (a) the Customer has failed to make available records of verification tests and maintenance of his protective devices; (b) the Unit system interferes with the Company equipment or equipment belonging to other customers of the Company; (c) the Unit adversely affects the quality of service of adjoining customers.

4.3 Disconnection by Customer: The Customer may disconnect the Unit at any time.

Issued by: Arthur R. Upright, Senior Vice President, Poughkeepsie, New York