

..DID: 14356  
..TXT: PSC NO: 15 ELECTRICITY LEAF: 19.16  
COMPANY: CENTRAL HUDSON GAS & ELECTRIC CORPORATION REVISION: 0  
INITIAL EFFECTIVE DATE: 12/29/00 SUPERSEDING REVISION:  
STAMPS: Issued in Compliance with Order in C. 94-E-0952 dated November 15, 200  
Cancelled by 1 Rev. Leaf No. 19.16 Effective 01/24/2002  
RECEIVED: 12/28/00 STATUS: Cancelled EFFECTIVE: 12/29/00

**3. APPLICATION FOR SERVICE** (cont'd)

C. Distributed Generation Interconnection Requirements (cont'd)

I. PHOTOVOLTAIC INTERCONNECTION STANDARDS FOR RESIDENTIAL SOLAR  
ELECTRIC POWER PRODUCING FACILITIES OF 10 kW OR LESS (cont'd)

2. Manual Disconnect Device (cont'd)

C. The disconnect switch shall be readily accessible for operation by utility personnel at all times and be capable of being padlocked only in the open position. Operation of this switch is at the sole discretion of the utility without prior notice.

D. The disconnect switch shall be clearly marked, "Generator Disconnect Switch" with permanent 3/8 inch letters or larger.

3. Dedicated Distribution Transformer

A. The connecting utility reserves the right to require that the power producing facility connects to the utility's system through a dedicated distribution transformer if the utility decides that the transformer is necessary to ensure conformance with utility safe work practices, to enhance service restoration operations or to prevent detrimental effects to other utility customers.

4. Network Application

A. The utility reserves the right to exclude the power producing facility from connection to secondary network utility systems.

5. Power Producing Facility Performance

A. The electrical output of the power producing facility shall meet the latest IEEE Standard 519 and ANSI C84.1 at the time of placement into service.

Issued by: Arthur R. Upright, Senior Vice President, Poughkeepsie, New York