

PSC NO: 12 – Electricity
Consolidated Edison Company of New York, Inc.
Initial Effective Date: 05/17/2022
Issued in compliance with Order in Case 15-E-0751 dated 05/13/2022

Leaf: 17.3
Revision: 5
Superseding Revision: 3

PASNY DELIVERY SERVICE

General Provisions - Continued

Net Metering and Value Stack Tariff for PASNY Customer-Generators

Applicability:

- (1) To any PASNY Customer with farm waste electric generating equipment (as defined in Public Service Law Section 66-j) with a rated capacity of not more than 2,000 kW, provided such equipment is located and used (a) at the Customer's Farm Operation or (b) at the Customer's non-residential premises that is not its Farm Operation ("Non-farm Location");
- (2) To any PASNY Customer with solar electric generating equipment or wind electric generating equipment with a rated capacity of not more than 2,000 kW located and used at its premises;
- (3) To any PASNY Customer with fuel cell electric generating equipment (as defined in Public Service Law Section 66-j) located and used at the PASNY Customer's premises, provided that such equipment has a rated capacity of not more than 2,000 kW;
- (4) To any PASNY Customer with micro-hydroelectric ("micro-hydro") generating equipment located and used at the PASNY Customer's premises, provided that such equipment has a rated capacity of not more than 2,000 kW;
- (5) To any PASNY Customer with solar, farm waste, fuel cell, micro-hydroelectric ("micro-hydro") or wind electric generating equipment (as defined in Public Service Law Section 66-j and 66-l) located and used at its premises, with a rated capacity of up to 5,000 kW installed on or after November 1, 2019; and
- (6) To any PASNY Customer with (a) biomass electric generating equipment rated up to 5,000 kW as defined in the NYSEDA Clean Energy Standard Tier 1 eligibility criteria, including biogas and liquid biofuel, with an in-service date after January 1, 2015; (b) tidal/ocean electric generating equipment rated up to 5,000 kW as defined in the NYSEDA Clean Energy Standard Tier 1 eligibility criteria, with an in-service date after January 1, 2015; (c) generating equipment rated up to 5,000 kW listed in (a) and (b) as a resource ineligible for Clean Energy Standard Tier 1 solely by virtue of having an in-service date prior to January 1, 2015; (d) Stand-alone Electric Energy Storage rated up to 5,000 kW; and (e) a Hybrid Facility installed on or after November 1, 2019. Such PASNY Customers taking service under this applicability section must also take service under SC 11 of the Schedule of Electricity.

Options (1) to (5) are not available to PASNY Customers who take service under SC 11 of the Schedule for Electricity.