

PSC NO: 10 – Electricity
Consolidated Edison Company of New York, Inc.
Initial Effective Date: 02/27/2022

Leaf: 153
Revision: 4
Superseding Revision: 3

GENERAL RULES

20. Standby Service and Standby Service Rates - Continued

20.2 Interconnection and Operation

To receive Standby Service, the generator may be connected either for: (a) parallel operation with the Company's service, or (b) isolated operation with standby service provided by the Company by means of a double-throw switch.

Customers who take Standby Service are subject to the interconnection and operation requirements as described in General Rule 8.4.

Issued by: Robert Hoglund, Senior Vice President & Chief Financial Officer, New York, NY

Suspended to 06/27/2022 by order in Case 22-E-0064. See Supplement No. 75. The supplement filing date was 02/17/2022.
Suspended to 12/27/2022 by order in Case 22-E-0064. See Supplement No. 76. The supplement filing date was 06/09/2022.
Suspended to 04/26/2023 by order in Case 22-E-0064. See Supplement No. 77. The supplement filing date was 12/14/2022.
Suspended to 07/25/2023 by order in Case 22-E-0064. See Supplement No. 78. The supplement filing date was 04/24/2023.
Cancelled by supplement No. 79 effective 07/24/2023