PSC NO: 10 – Electricity Consolidated Edison Company of New York, Inc. Initial Effective Date:02/27/2022 Leaf: 444 Revision: 2 Superseding Revision: 1

# SERVICE CLASSIFICATION NO. 9 GENERAL - LARGE

## Applicable to Use of Service for

Light, heat, and power for general uses for which no other service classification specifically applies and where the Customer's initial requirements are expected to be in excess of 10 kilowatts subject to the Common Provisions and Special Provisions of this Service Classification.

## **Character of Service**

Of the various characteristics of service listed and more fully described in General Rule 4, the following may be designated for service by the Company under this Service Classification, subject to the limitations set forth in such Rule. Frequencies and voltages shown are approximate. All are continuous.

## **Standard Service**

Any derivative of the standard alternating current, 3 phase, 4 wire system at 60 cycles and 120/208 volts.

#### **Non-Standard Service**

Low Tension Alternating Current - 60 cycles:

Single phase at 120/240 volts Three phase at 265/460 volts Three phase at 240 volts Two phase at 120/240 or 230 or 240 volts

High Tension Alternating Current - 60 cycles:

Three phase at 2,400/4,150 volts Three phase at 3,000 or 7,800 volts Three phase at 6,900 volts Three phase at 13,200 volts Three phase at 26,400 volts Three phase at 33,000 volts Single phase and three phase at 2,400 volts Three phase at 69,000 volts Three phase at 138,000 volts