

PSC No: 120 – Electricity  
New York State Electric & Gas Corporation  
Initial Effective Date: September 1, 2023  
Issued in compliance with Order in Case No. 18-E-0130, dated September 17, 2020.

Leaf No. 117.55.1  
Revision: 0  
Superseding Revision:

## GENERAL INFORMATION

### 48. Term and Auto- Dynamic Load Management Programs

#### C. Application and Terms of Service (Cont'd)

7. If a Direct Participant or Aggregator requests to operate Electric Generating Equipment for Load Relief purposes under this Program, the application must state generator information, including the unit's serial number, nameplate rating, manufacturer, date of manufacture, fuel type or energy source, the kW enrolled using this equipment, and identification as to whether the unit incorporates three-way catalyst emission controls (natural gas-fired rich burn), a natural gas lean-burn engine of model year vintage 2000 or newer, or a diesel-fired engine of model year vintage 2000 or newer, or whether it has a NOx emission level of no more than 2.96 lb/MWh. If the generating equipment has a NOx emission level of no more than 2.96 lb/MWh, but is not natural gas-fired rich burn generating equipment that incorporates three-way catalyst emission controls, a natural gas lean-burn engine of model year vintage 2000 or newer, or a diesel-fired engine of model year vintage 2000 or newer, written certification by a professional engineer must be attached to the application attesting to the accuracy of all generation-related information contained in the application, including the NOx emission level.